

## TSTFs Under Review by NRC

DATE RECEIVED	TSTF #	TSTF TITLE	NRC REVIEWER	CLIIP	TARGET DATE
04/04/2003	TSTF-357, R.1	Revision to TS 2.1.1.2, MCPR Safety Limit	Kavanagh	<input checked="" type="checkbox"/>	08/29/2004
12/05/2004	TSTF-369, R.1	Removal of Monthly Operating Report and Occupational Radiation Exposure Report	Hearn	<input checked="" type="checkbox"/>	01/04/2005
11/19/2003	TSTF-372, R.3	Addition of LCO 3.0.8, Inoperability of Snubbers	Kavanagh	<input checked="" type="checkbox"/>	11/16/2004
04/20/2001	TSTF-374	TSTF-374, Revision to TS 5.5.13 and associated TS Bases for Diesel Fuel Oil	Le	<input checked="" type="checkbox"/>	05/30/2004
05/19/2001	TSTF-400	TSTF-400, Clarify SR on Bypass of DG Automatic Trips - as per our previous discussions regarding TSTFs - Modifying	Le	<input type="checkbox"/>	05/30/2004
11/10/2003	TSTF-409, R.2	Containment Spray System Completion Time Extension (CE NPSD-1045-A)	Schulten	<input checked="" type="checkbox"/>	05/30/2004
01/23/2003	TSTF-422, R.1	Risk-Informed Modification to Selected Action End States for CEOG PWRs	Tjader	<input checked="" type="checkbox"/>	06/30/2004
08/13/2003	TSTF-423	Technical Specifications End States, NEDC-32988-A - (BWR Initiative 1)	Tjader	<input checked="" type="checkbox"/>	01/01/2005
01/23/2003	TSTF-424	Risk-Informed HPSI AOT/CT Extension (WCAP-15773) - Initiative 4B	Tjader	<input checked="" type="checkbox"/>	09/30/2004
03/06/2003	TSTF-427	TSTF-427, Allowance for Non Technical Specification Barrier Degradation on Supported System OPERATILIBY - Initiative 7	Kavanagh	<input checked="" type="checkbox"/>	09/30/2004
01/05/2004	TSTF-430, R.2	AOT Extension to 7 Days for LPI and Containment Spray (BAW-2295-A, Rev. 1)	Tjader	<input checked="" type="checkbox"/>	01/04/2005
06/06/2002	TSTF-433	Eliminate SR 3.8.2.1, Note 2, from the PWR ITS NUREGs	Le	<input type="checkbox"/>	05/30/2004
11/01/2002	TSTF-439, R.1	Eliminate Second Completion Times Limiting Time from Discovery of Failure to Meet an LCO	Schulten	<input checked="" type="checkbox"/>	09/30/2004
10/23/2002	TSTF-446	TSTF-446, Risk Informed Evaluation of Extensions to Containment Isolation Valve Completion Times (WCAP-15791)	Harbuck	<input checked="" type="checkbox"/>	09/30/2004
08/19/2003	TSTF-448, R.1	Control Room Habitability	Harbuck	<input type="checkbox"/>	08/18/2004

## TSTFs Under Review by NRC

DATE RECEIVED	TSTF #	TSTF TITLE	NRC REVIEWER	CLIIP	TARGET DATE
09/15/2003	TSTF-449, R.1	Steam Generator Tube Integrity	Kavanagh	<input checked="" type="checkbox"/>	09/30/2004
07/16/2003	TSTF-450	Staggered integrated ESFAS Testing (WCAP-15830)	Schulten	<input checked="" type="checkbox"/>	07/30/2004
09/05/2003	TSTF-454	Increase PCIV Completion Times from 4 hours, 24 hours, and 72 hours to 7 days (NEDC-33046)	Harbuck	<input checked="" type="checkbox"/>	09/30/2004
09/19/2003	TSTF-459	Eliminate the requirement to have one RHR Shutdown Cooling System in operation	Kavanagh	<input checked="" type="checkbox"/>	09/30/2004
09/19/2003	TSTF-460	Control Rod Scram Time Testing Frequency	Tjader	<input checked="" type="checkbox"/>	09/30/2004
09/19/2003	TSTF-465	Addition of time performance Surveillance Requirement (SR) note to Source Range Monitor (SRM) SRs	Schulten	<input checked="" type="checkbox"/>	09/30/2004